

SLOTTED SIDE MOUNTING RAP-TIE APPLICATION

Introduction

The Slotted Side Mounting Rap-Tie (Rod Adjustable Plate Tie) system consists of a vertically orientated steel Flat-plate, a V-Tie™ (a V-shaped steel wire), and an Insulation Support (optional, but recommended). These individual components are shown in Figures 1, 2 and 3, respectively. The installed tie system is shown in the Cover Illustration and Figure 4.

Tensile and compressive lateral loads acting on the masonry veneer are transferred through the V-Tie™ to the Slotted Flat-Plate, which is fastened directly to the structural backing without any intervening material such as sheathing. The Flat-Plate is fastened to the side surface of a structural backing member such as a steel stud web or wood stud (see Cover illustration, and Figure 4). The vertical slot along the outboard end of the Slotted Flat-Plate, through which the V-Tie™ is inserted, provides a positive connection without the possibility of V-Tie™ disengagement during construction and in-service (in accordance with requirements in CSA A370, "Connectors for Masonry" and ACI 530/ASCE 5/TMS 402, "Building Code Requirements for Masonry Structures"). The slot permits up to 30 mm (1.2") of in-situ vertical adjustment so that a bed joint in the masonry veneer will always be coincident with the V-Tie™ regardless of the vertical placement of the Flat-Plate along the supporting structural member. The vertical slot also accommodates vertical differential movement between the masonry veneer and the structural backing.

The Insulation Support, inserted over the end of the Flat-Plate and restrained by the V-Tie™, is optionally used to securely and mechanically fix cavity rigid insulation in place.




Figure 3 Insulation Support/Retainer




Figure 4
Slotted Side Mounting Rap-Tie System
without Insulation Support

A 5.8 mm (0.23") wide x 35 mm (1.4") long vertical slot is punched along the leading edge of the Slotted Flat-Plate to receive the V-Tie™.

V-Tie™: The V-Tie™ (Figure 2) is manufactured from 4.76 mm (0.19") diameter steel wire and is available in both hot-dip galvanized finish and stainless steel. The weight of the hot-dip galvanized finish is not less than 460 g/m² (1.5 oz/ft.²) and satisfies the requirements of CSA A370 (which references ASTM A123), ACI 530.1/ASCE 6/TMS 602 (which references ASTM A153, 458 g/m²) and the International Building Code (IBC) (which reference ASTM A153, Class B, 458 g/m²).

The V-Tie™ is available in a variety of standard lengths to accommodate different specified thicknesses of masonry veneer and design widths of air space. The V-Tie™ specification length, (L), should be selected to provide for placement of the legs of the V-Tie™ along the centreline of the masonry veneer. Varying lengths of V-Tie™, appropriately selected by the mason on the jobsite, facilitate in-situ adjustment normal to the structural backing where the constructed width of air space differs from the design width of air space (to accommodate construction tolerances). Standard lengths of V-Tie™ include 60 mm (2.4"), 80 mm (3.1"), 100 mm (3.9"), 120 mm (4.7"), 140 mm (5.5"), 160 mm (6.3"), 180 mm (7.1"), 200 mm (7.9"), 225 mm (8.9") and 250 mm (9.8"). For example, the 50 mm (2.4") V-Tie™ is used in a Slotted Side Mounting Rap-Tie system consisting of 25 mm (1") air space and 90 mm (3.5") masonry veneer.

Insulation Support: The Insulation Support (Figure 3) is manufactured from polyethylene. It is pressed by hand over the outboard end of the Flat-Plate tightly against the cavity insulation to prevent the insulation from separating from the structural backing/air barrier/sheathing membrane. The friction fit between the Insulation Support and the Flat-Plate restrains the insulation during construction which is commonly installed in advance of the exterior masonry veneer. Subsequent installation of the V-Tie™ sandwiches the Insulation Support between the insulation and the V-Tie™, thereby locking the Insulation Support in-place and ensuring a reliable and permanent insulation support system.

The Insulation Support is a standard component of the system, but it is optional where the insulation is otherwise supported, and not required where no insulation is placed within the cavity. Figure 4 shows the system without the Insulation Support.

The Slotted Side Mounting Rap-Tie system is designed to transfer the lateral load from the exterior masonry veneer axially and normal to the structural backing. The connection between the V-Tie™ and Slotted Flat-Plate by way of the vertical slot does not resist differential movement between the structural backing and the masonry veneer in the vertical direction, and therefore, does not offer composite action between the structural backing and the masonry veneer. For the design of shear connected masonry veneer/(steel) stud systems (i.e. composite wall construction), see Fero Stud Shear™ Connector product literature.

The fasteners connecting the Slotted Side Mounting Rap-Tie to the side surfaces of the structural backing member resist loads in shear. This fastener orientation, and their inboard position within the wall system, provide a more desirable connection to the structural backing than surface-mounted tie systems which subject the fasteners to direct tension and generally higher moisture loads.

Structural Action

Side Mounting Rap-Tie System Design Data

Side Mounting Rap-Tie System Design Data (Canada)

Design Parameter	Design Data Side Mounted (i),(iii)	
1. Mechanical Free Play: ⁽ⁱⁱⁱ⁾ (with FERO V-Tie™)	1.04 mm (max) (0.041")	
2. Serviceability at 0.45 kN (100 lbs) ⁽ⁱⁱⁱ⁾		
Displacement	0.16 mm (0.0063")	
Displacement + Mechanical Free Play	1.2 mm (max) (0.047")	
3. Factored Resistance (ϕP_{ult}) ^{(iv),(v),(vi)}	2.13 kN (475 lbs.)	
4. Maximum Recommended Spacing: ^(vii)	Horizontal:	Vertical:
	800 mm (32")	600 mm (24")

- (v) The stated tie factored resistance is based on the capacity of FERO tie components, and does not consider fastener resistance. A compatible fastener having an adequate factored resistance must be selected (by design in accordance with CSA A370-14).
- (vi) The factored resistance of the mortar pull-out or push-through for the V-Tie™ embedded at the centreline of 90 mm (3.5") brick veneer utilizing Type S or N mortar exceeds or equals the tabled factored resistance, ϕP_{ult} . Failure by pull-out/push-through of the mortar joint does not govern.
- (vii) Maximum recommended tie spacings are the maximum spacings permitted by CSA S304-14, *Design of Masonry Structures*. For a particular design, the actual tie spacings are calculated such that the factored resistance of the tie, ϕP_{ult} , equals or exceeds the effect of factored loads. See S304-14 for the design of masonry veneer systems.

Side Mounting Rap-Tie System Design Data (U.S.)

Design Parameter	Design Data Side Mounted (i),(iii)	
1. Mechanical Free Play: ⁽ⁱⁱⁱ⁾ (with FERO V-Tie™)	0.041" (max) (1.04 mm)	
2. Serviceability at 100 lbs (0.45 kN) ⁽ⁱⁱⁱ⁾		
Displacement	0.0063" (0.16 mm)	
Displacement + Mechanical Free Play	0.047" (max) (1.2 mm)	
3. Nominal Strength ^{(iv),(v),(vi),(vii),(ix)}	635 lb (2.84 kN)	
4. Recommended Design Load ^{(iv),(v),(vi),(vii),(ix)}	280 lb (1.26 kN)	
5. Maximum Recommended Spacing: ^(vii)	Horizontal:	Vertical:
	32" (813 mm)	18" (457 mm)

- (iv) The nominal strength of the Slotted Side Mounting Rap-Tie is determined by test and is reported as the average ultimate strength of the tie samples. In accordance with ACI 530/ASCE 5/TMS 402, using Strength Design, a suitable strength-reduction factor must be applied to the nominal strength to determine the tie design strength. Similarly, under Allowable Stress Design, an appropriate safety factor must be applied to determine an allowable load value. The tabled "Recommended Design Load" reflects a safety factor of 2.25 (that is, 75% of 3.0). [See also Note (v) when assigning a strength-reduction factor to the nominal strength].
- (v) The stated nominal strength and recommended design load do not consider fastener capacity. A compatible fastener (or fasteners) having an adequate strength must be selected (by design in accordance with ACI 530.1/ASCE 6/TMS 602).
- (vi) The nominal strength (and corresponding recommended design load) of the mortar pull-out or push-through for the V-Tie™ embedded at the centerline of 3.5" (90 mm) brick veneer utilizing Type M, S or N mortar exceeds or equals the tabled nominal strength (and recommended design load). Failure by pull-out/push-through of the mortar joint does not govern.
- (vii) Maximum recommended tie spacings are the maximum spacings permitted by ACI 530/ASCE 5/TMS 402 using prescriptive requirements for anchored masonry veneer. The prescriptive requirements in ACI 530/ASCE 5/TMS 402 further limit a tie tributary area to not more than 2.67 ft² (0.25 m²) wall area [with reduced areas for high Seismic Design Categories and in areas of high winds] unless the veneer is alternatively designed using a rational, engineered method (termed "Alternative Design of Anchored Masonry Veneer"). Where an Alternative Design is used, the required tie spacing may be calculated such that the design strength of the tie equals or exceeds the required strength. See ACI 530/ASCE 5/TMS 402 for the design of masonry veneer systems.
- (viii) The Slotted Side Mounting Rap-Tie system satisfies ACI 530/ASCE 5/TMS 402 requirements for minimum wire size of W1.7 (MW11) and for ends bent to form a minimum 2 in (50.8 mm) extension.
- (ix) ACI 530/ASCE 5/TMS 402 requires joint reinforcement in masonry veneer in high Seismic Design Categories to be mechanically attached to the masonry tie.

Design data for the Slotted Side Mounting Rap-Tie system are reported separately for Canada and the United States in the following tables because design methods and requirements for masonry ties and their uses differ between their respective codes and standards.

Notes:

- (i) These design data are based on connector testing in accordance with CSA A370-14, *Connectors for Masonry*, with no surcharge and with test samples having the following configuration: 140 mm [5.5"] cavity (with configuration for 25 mm [1"] air space); standard FERO V-Tie™; and V-Tie™ engaged into Plate at position of maximum vertical adjustment; no insulation or gypsum board present. Smaller cavity widths and/or the addition of insulations providing lateral support to the Plate will increase the tabled factored resistance of the tie and reduce tie displacement.
- (ii) These design data reflect both the windward (compression) and leeward (tension) capacities of the Slotted Side Mounting Rap-Tie system, with the governing values listed.
- (iii) The Slotted Side Mounting Rap-Tie system satisfies the limiting requirements for serviceability (tie displacement and mechanical free play) in CSA A370-14. Tabled mechanical free play is for stainless steel components. The mechanical free play for hot-dip galvanized components is less.
- (iv) The ultimate strength of the Slotted Side Mounting Rap-Tie system, P_{ult} , is determined in accordance with CSA A370-14 and is calculated by multiplying the average tie strength established by testing by (1 – 1.64 cov). The factored resistance of the tie system (ϕP_{ult}) is calculated using the Limit States Design procedures of CSA A370-14.

Notes:

- (i) These design data are based on connector testing in accordance with CSA A370-04, *Connectors for Masonry*, with no surcharge and with test samples having the following configuration: 140 mm [5.5"] cavity (with configuration for 25 mm [1"] air space); standard FERO V-Tie™; and V-Tie™ engaged into Plate at position of maximum vertical adjustment; no insulation or gypsum board present. The test method for ties in CSA A370-04 is comparable to that of ASTM E754, *Test Method for Pullout Resistance of Ties and Anchors Embedded in Masonry Mortar Joints*, and provides similar and more conservative results. Smaller cavity widths and/or the addition of insulations providing lateral support to the Plate will increase the tabled factored resistance of the tie and reduce tie displacement. Prescriptive requirements for anchored masonry veneer under ACI 530/ASCE 5/TMS 402 limit the cavity to a maximum width of 4-1/2" (114 mm) unless the veneer is alternatively designed using a rational, engineered design method (termed "Alternative Design of Anchored Masonry Veneer").
- (ii) These design data reflect both the windward (compression) and leeward (tension) capacities of the Slotted Side Mounting Rap-Tie system, with the governing values listed.
- (iii) The Slotted Side Mounting Rap-Tie system satisfies the 1/16" (1.6 mm) maximum permissible clearance between connecting parts required by ACI 530/ASCE 5/TMS 402. Tabled mechanical free play is for stainless steel components. The mechanical free play for hot-dip galvanized components is less.

Fero Corporation

15305 - 117 Avenue, Edmonton, Alberta T5M 3X4

Phone: (780) 455-5098 Fax: (780) 452-5969

www.ferocorp.com info@ferocorp.com

Patent Pending

©2014 Fero Corporation

